

[REDACTED]

WDAT 462 ISP – [REDACTED]

*WDAT
Facility Study*

Revised March 29, 2012



SOUTHERN CALIFORNIA
EDISON
An EDISON INTERNATIONAL® Company

Prepared by:

*Sergio Rodas
Roger Salas, P.E.
Distribution Field Engineering*

Approved by:

*Russ Ragsdale
Distribution Field Engineering Manager*

SOUTHERN CALIFORNIA EDISON COMPANY

EXECUTIVE SUMMARY

[REDACTED] applied to Southern California Edison ("SCE") for interconnection and wholesale distribution service for its proposed Solar Project pursuant to SCE's Wholesale Distribution Access Tariff ("WDAT") Generation Interconnection Procedures. SCE performed an Independent Facilities Study as requested by [REDACTED] for a 12 kV interconnection and distribution service from the SCE 12 kV system. The interconnection is an applicant owned 12 kV switchgear, which will be [REDACTED], connected to a 12 kV circuit out of SCE's Bunker 115/12 kV Substation. The request is for a WDAT photovoltaic ("PV") generation facility with a total capacity of 8.0 MW. The initial request is for service to commence by June 30, 2012¹.

The new generation, consisting of photovoltaic panels, [REDACTED] inverters, and [REDACTED] kV transformer would receive interconnection service from SCE's existing Chaney 12 kV out of Bunker Substation via an underground line extension to the applicant owned 12 kV switchgear. The generated power would be delivered to the California Independent System Operator ("CAISO") grid at the 500 kV bus of SCE's Valley Substation.

The purpose of this Independent Facilities Study is to determine:

- The need to install an Automatic Recloser.
- The estimated cost for the Distribution Upgrades and Interconnection Facilities which were identified in the Independent System Impact Study².
- The estimated time required to complete the design and construction of the Distribution Upgrades and Interconnection Facilities which were identified in the Independent System Impact Study.

¹ Date as requested in the application. Actual operating date depends on design, procurement, and construction requirements. Interconnection Studies will ultimately determine in-service date.

² Copy of the Independent System Impact Study is provided as attachment A.

Non-binding order of magnitude cost estimates for the required interconnection facilities and 12 kV system upgrades are as follows:

<u>Distribution Upgrades</u>	\$88.0 K ¹
○ 4-way Automated Pad Mounted Gas Switch	
○ Remote Automatic Recloser	\$84.0 K ¹
<u>Distribution Upgrades (Substation)</u>	\$26.0 K ¹
○ Bi-directional Transducer	
○ Testing and Programming	
<u>Interconnection Facilities Upgrades</u>	\$124.0 K ¹
○ Approximately 300 feet of primary cable (1000 JCN)	
○ Remote Control Switch	
○ 12 kV Metering, CTs, PTs, and associated wiring	
<u>Telemetry Requirements²</u>	\$ 11.0 K ¹
○ Data Programming	
<hr/> Total non-binding order of magnitude cost estimate	\$333.0 K¹

¹ Cost Estimate includes 35% ITCC. Cost estimate are in 2012 Dollars.


² Applicant will utilize existing RTU and DPG installed under WDAT 375 to provide the telemetry data. Only programming will be required

CONTENTS

	<u>PAGE</u>	
I. INTRODUCTION	4	
VI. PART A: SUMMARY	5	
Attachment A: Independent System Impact Study		

I. INTRODUCTION

[REDACTED] applied to Southern California Edison ("SCE") for interconnection and wholesale distribution service for its proposed Solar Project pursuant to SCE's Wholesale Distribution Access Tariff ("WDAT") Generation Interconnection Procedures. SCE performed an Independent Facilities Study as requested by [REDACTED] for a 12 kV interconnection and distribution service from the SCE 12 kV system. The interconnection is an applicant owned 12 kV switchgear, which will be [REDACTED] connected to a 12 kV circuit out of SCE's Bunker 115/12 kV Substation. The request is for a WDAT photovoltaic ("PV") generation facility with a total capacity of 8.0 MW. The initial request is for service to commence by June 30, 2012¹.



The new generation, consisting of photovoltaic panels, [REDACTED] inverters, and [REDACTED] kV transformer would receive interconnection service from SCE's existing Chaney 12 kV out of Bunker Substation via an underground line extension to the applicant owned 12 kV switchgear. The generated power would be delivered to the California Independent System Operator ("CAISO") grid at the 500 kV bus of SCE's Valley Substation.

¹ Date as requested in the application. Actual operating date depends on design, procurement, and construction requirements. Interconnection Studies will ultimately determine in-service date.

The purpose of this Independent Facilities Study is to determine:

- The need to install an Automatic Recloser.
- The estimated cost for the Distribution Upgrades and Interconnection Facilities which were identified in the Independent System Impact Study¹.
- The estimated time required to complete the design and construction of the Distribution Upgrades and Interconnection Facilities which were identified in the Independent System Impact Study.

I. RESULTS

System Protection Considerations

Some changes to the protection system of the SCE electrical system are required due to the additional generation. The study identified that the addition of the [REDACTED] Project triggered a problem, not allowing the proper relay coordination of the Chaney relay at Bunker Substation and the generating facility main breaker. Therefore, an Automatic Recloser is required to achieve proper coordination and detect end of the line faults to prevent coordination overlaps and erroneous trips downstream in the [REDACTED] system.

¹ Copy of the Independent System Impact Study is provided as attachment A.

VI. SUMMARY

1. Distribution Upgrades will include the installation of [REDACTED] 4-way pad Mounted Gas Switch, [REDACTED]-phase Bi-directional transducer and a 12 kV Automatic recloser
2. Interconnection Facilities will include the approximately 300 feet of underground primary 1000 JCN cable, a RCS controller, 12 kV metering CTs and VTs, metering, and associated wiring.
3. Real time telemetry will be required. It will be required to install an RTU and Telecom systems as required to provide Watts and VARS flow from the generation facility to the SCE distribution system.
4. Interconnection service and distribution service pursuant to the WDAT would be expected to commence within 6-8 months of executing a Generator Interconnection Agreement (“GIA”) and associated Distribution Service Agreement. The time required to install the Watt Transducer will be negotiated in the SGIA.
5. Non-binding order of magnitude cost estimates for the required interconnection facilities and 12 kV system upgrades are as follows, these do not include any costs driven by Part B of the study.

12 kV Distribution Upgrades	\$172.0 K
Substation Distribution Upgrades	\$26.0 K
Interconnection Facilities/Automation	\$124.0K
<u>Telemetry Requirements¹</u>	\$11.0 K
Total non-binding order of magnitude cost estimate	\$333. K²

¹ Applicant will utilize existing RTU and DPG installed under WDAT 375 to provide the telemetry data. Only programming will be required

² Cost Estimate includes 35% ITCC. Cost estimate are in 2012 Dollars.

6. The design of the Interconnection Facilities will take be approximately 60 business days from the execution of the Small Generator Interconnection Agreement (SGIA) and from the time the applicant has provided the following to SCE:
 - *Approved panel drawings which shall comply with SCE ESR. These requirements can be downloaded at :*
<http://www.sce.com/AboutSCE/Regulatory/distributionmanuals/esr.htm>
 - *Customer information sheet.*
 - *Street improvement plans (if available)*
 - *Unique address for point of interconnection*
 - *Public Right away (Street) base maps as required by the interconnection.*
 - *Site plot plan on a 30:1 Scale or Digital file*
 - *Easements/Lease agreement*
 - *Grading plans*
 - *Sewer and storm plot plans*
 - *Landscape, Sprinkler, Pedestal Locations*
 - *Underground civil construction is released by SCE inspectors.*
7. The construction of the electrical facilities will take approximately 60 business days. The Interconnection Customer is responsible to perform the underground civil work per SCE's design. SCE will then approve and release the applicant installed underground infrastructure prior to SCE initiating the construction of the electrical facilities. The underground civil work includes but it is not limited to excavation (all necessary trenching, backfilling, and other digging as required) and installation of conduits and vaults for the required interconnection facilities.
8. Where formal rights of way, easements, land leases, or permits are required by SCE for installation of facilities, on or over Applicant's property, or the property of others, the Applicant shall grant SCE the rights of way and easements for the electrical facilities.
9. Current distribution standards are being updated to address generation interconnection systems. The proposed method of service on this report may change according on final design to comply with the updated distribution design standards.
10. No environmental studies are required with the proposed method of service.

Attachment A – Independent System Impact Study

[REDACTED]

WDAT 462 ISP

*WDAT
INDEPENDENT SYSTEM IMPACT STUDY*

February 2, 2012



Prepared by:

*Sergio Rodas
Roger Salas, P.E.
Distribution Field Engineering*

Approved by:

*Russ Ragsdale
Distribution Field Engineering Manager*

SOUTHERN CALIFORNIA EDISON COMPANY

EXECUTIVE SUMMARY

[REDACTED] applied to Southern California Edison ("SCE") for interconnection and wholesale distribution service for its proposed Solar Project pursuant to SCE's Wholesale Distribution Access Tariff ("WDAT") Generation Interconnection Procedures. SCE performed an Independent System Impact Study as requested by [REDACTED] for a 12 kV interconnection and distribution service from the SCE 12 kV system. The interconnection is an applicant owned 12 kV switchgear, which will be [REDACTED] connected to a 12 kV circuit out of SCE's Bunker 115/12 kV Substation. The request is for a WDAT photovoltaic ("PV") generation facility with a total capacity of 8.0 MW. The initial request is for service to commence by [REDACTED]¹.

The new generation, consisting of thin film photovoltaic panels, [REDACTED] inverters, and [REDACTED] kV transformer would receive interconnection service from SCE's existing Chaney 12 kV out of [REDACTED] on via an underground line extension to the applicant owned 12 kV switchgear. The generated power would be delivered to the California Independent System Operator ("CAISO") grid at the 500 kV bus of SCE's Valley Substation.

The purpose of this Independent System Impact Study is to determine the effect of the proposed generation addition on the SCE distribution system and the portion of SCE's electrical system that is part of the CAISO controlled grid, and to identify in general additional Interconnection Facilities, Distribution Upgrades, additions or modifications, or other facilities required to provide the requested service. The study was performed in two parts: Part A (performed by SCE's Distribution Field Engineering department) examines impacts related to that part of the SCE distribution system energized at less than 115 kV and also briefly summarizes the results of Part B, while Part B (performed by SCE's Generation Interconnection Planning department) examines impacts and facilities related to the portion of the SCE electrical system energized at 500 kV and above (the bulk power system), and impacts and facilities associated with the CAISO controlled portion of the SCE grid. This is the Part A study report; a detailed report of the Part B study results is included as Attachment B.

The Part A study was performed for expected year 2012 through 2021 projected peak load conditions as well as 2012 through 2021 minimum load conditions.

The Part A Independent System Impact Study consisted of a power flow analysis, three-phase short circuit duty analysis based on most current thevenin equivalents and circuit voltage profile analysis. The analyses were performed to determine whether the energy associated with the SPVP 044 ([REDACTED]) Project can be transmitted through SCE's distribution system to the ISO grid at the 500 kV bus of Valley Substation, without creating the need for modifications to SCE's distribution system and/or to the ISO grid. The study showed that, with the SPVP 044 ([REDACTED]) Project on-line:

¹ Date as requested in the application. Actual operating date depends on design, procurement, and construction requirements. Interconnection Studies will ultimately determine in-service date.

- For both peak load and light load conditions, the addition of the 8.0 MW SPVP 044 ("██████") Project resulted in no violations of SCE's thermal loading criteria under base case and N-1 conditions for the SCE distribution System.
- The addition of the 8.0 MW SPVP 044 ("██████") Project resulted in minimal voltage rise not exceeding allowable Rule 2 limits.
- The addition of the 8.0 MW SPVP 044 ("██████") Project resulted in the increase of three-phase short-circuit duties at ████████ distribution substation. The circuit breaker interrupting capabilities were reviewed at these substation and it was determined that zero (0) circuit breakers will be required to be upgraded based on most current thevenin equivalents. The final results and financial responsibilities will be determined on the Cluster study process in accordance to the WDAT ISP study procedures.
- Based on the size and point of interconnection of the project it is assumed that the SCD impacts will be limited to the SCE distribution system. The SCD impacts of the project on the CAISO controlled transmission system are assumed to be negligible.
- With all active queued ahead generation projects and all corresponding facility upgrades modeled regardless of operating date, the queue order power flow study did not identify any new thermal overloads triggered by the Project under base case or outage conditions in the Northern Bulk Transmission system. An operational study was not required.

- Non-binding order of magnitude cost estimates for the required interconnection facilities and system upgrades are as follows:

Distribution Upgrades \$ 88.0 K²

- 4-way Automated Pad Mounted Gas Switch

Distribution Upgrades (Substation) \$ 23.0 K²

- Bi-directional Transducer

Interconnection Facilities Upgrades \$ 124.0 K²

- Approximately 300 feet of primary cable (1000 JCN)
- Remote Control Switch
- 12 kV Metering, CTs, PTs, and associated wiring

Telemetry Requirements³ \$ 5.0 K²

- Remote Terminal Unit
- Telecommunication System for RTU

Total non-binding order of magnitude cost estimate \$240.0 K⁴

² Cost Estimate includes 35% ITCC. Cost estimate are in 2012 Dollars.

³ Cost and scope of telemetry may be reduced. Details will be provided once the new telemetry system methods are completed.

⁴ Cost Estimate includes 35% ITCC. Cost estimate are in 2012 Dollars.

CONTENTS

	<u>PAGE</u>
I. INTRODUCTION TO PART A	6
II. PART A: INDEPENDENT SYTEM IMPACT STUDY CONDITIONS & METHODOLOGY	7
III. PART A: INDEPENDENT SYSTEM IMPACT STUDY RESULTS	8
IV. PART A: GENERAL DESCRIPTION OF IDENTIFIED UPGRADES	9
V. PART A: NON-BINDING ORDER OF MAGNITUDE COST ESTIMATE	10
VI. PART A: SUMMARY	11
Attachment A: Part A: SYSTEM DIAGRAMS	
• A1 System Without Proposed Project	
• A2 System With Proposed Method of Service	
Attachment B: BULK POWER SYSTEM IMPACT STUDY REPORT	

I. INTRODUCTION TO PART A

[REDACTED] applied to Southern California Edison ("SCE") for interconnection and wholesale distribution service for its proposed Solar Project pursuant to SCE's Wholesale Distribution Access Tariff ("WDAT") Generation Interconnection Procedures. SCE performed an Independent System Impact Study as requested by [REDACTED] for a 12 kV interconnection and distribution service from the SCE 12 kV system. The interconnection is an applicant owned 12 kV switchgear, which will be located approximately 2.10 miles from [REDACTED], connected to a 12 kV circuit out of SCE's Bunker 115/12 kV Substation. The request is for a WDAT photovoltaic ("PV") generation facility with a total capacity of 8.0 MW. The initial request is for service to commence by [REDACTED].

⁵ Date as requested in the application. Actual operating date depends on design, procurement, and construction requirements. Interconnection Studies will ultimately determine in-service date

The new generation, consisting of thin film photovoltaic panels, [REDACTED] inverters, and [REDACTED] kV transformer would receive interconnection service from SCE's existing Chaney 12 kV out of [REDACTED] via an underground line extension to the applicant owned 12 kV switchgear. The generated power would be delivered to the California Independent System Operator ("CAISO") grid at the 500 kV bus of SCE's Valley Substation.

The generated power would be delivered to the California Independent System Operator ("CAISO") grid at the 500 kV bus of SCE's Valley Substation. The new generation, consisting of thin film photovoltaic panels, [REDACTED] inverters, and [REDACTED] kV transformer would receive interconnection service from SCE's existing Chaney 12 kV out of [REDACTED] on via an underground line extension to the applicant owned 12 kV switchgear. The generated power would be delivered to the California Independent System Operator ("CAISO") grid at the 500 kV bus of SCE's Valley Substation.

The purpose of this Independent System Impact Study is to determine the impact of the proposed generation addition on the SCE distribution system and to identify in general additional Interconnection Facilities, Distribution Upgrades, additions or modifications, or other facilities required to provide the requested service. This study was performed for expected year 2012 through 2021 peak load conditions as well as low demand conditions.

II. PART A: SYSTEM IMPACT STUDY CONDITIONS & METHODOLOGY

Planning Criteria

The thermal rating of any conductor, connector, or apparatus should not exceed 100% of its normal rated capacity with all facilities in service (base case).

The thermal rating of any conductor, connector, or apparatus should not exceed 100% of its emergency rating under N-1 conditions.

Operational flexibility and reliability of the distribution system shall be maintained at all times.

Circuit voltage profiles should be maintained to comply within CPUC's Rule 2 requirements.

System Conditions

The power factor for the new generation facility was assumed to be within WDAT requirements of 0.95 lagging or leading.

Expected loading on the distribution system as projected by the SCE 2012 - 2021 plan was used.

Distributed Generation resources connected to the distribution system are analyzed offline and online during peak load conditions as well as during minimum daytime load conditions as to determine worst case scenario.

The Short circuit contribution from the inverter systems was determined using inverter manufacturer datasheets.

Thevenin equivalents for this study are based on most current thevenin equivalents. Final Short circuit study and cost responsibilities for breaker upgrades will be conducted in the cluster process in accordance with WDAT ISP.

III. PART A: SYSTEM IMPACT STUDY RESULTS

Short Circuit Analysis

Using the short circuit models from the inverter systems being utilized in this solar generation project, it was calculated that the short circuit contribution at [REDACTED] substation bus was more than 0.1 kA and concluded that [REDACTED] circuit breakers required replacement as a result of this project.

System Protection Considerations

With this proposed method of service, no changes to the protection system of the SCE electrical system are required.

Thermal Loading

The line section between the customer's facility and the 12 kV Point of Interconnection is expected to experience a reverse power flow of approximately 8.0 MW during minimum loading. Of that 8.0 MW [REDACTED] will flow back into the 12 kV bus at Bunker 115/12 kV Substation during minimum loading. Also, due to the power flow going back to the 12 kV bus at Bunker substation, the installation of one [REDACTED] will be required to monitor this reverse power flow⁶.

Distribution Voltage Control

The section of the 16 kV near the project area is expected to experience voltage rise of 2.1%, which would not exceed the allowable CPUC Rule 2 requirements as a result to the addition of the 13.2 MW [REDACTED] under the generating facilities conditions of maximum generation and unity power factor.

Harmonic impact

The harmonic impact of the subject inverter based generation was not part of this System Impact Study. Despite the relatively low THD (<3%) of the equipment, impacts on voltage distortion levels may be significant due to the high penetration level of the generation facility with respect to the local distribution grid strength. As with all equipment connected to the SCE distribution system, the generation project will be subject to the provisions of Rule 2.E, allowing SCE to require customer mitigation of interference with SCE service, including harmonic impacts, if harmonic interference is caused by the customer. Since the THD values which were provided are for individual inverters and not for the total generation requested, it will be required to determine the total harmonic contribution for the entire generation facility prior to approving the generation to interconnect to the SCE distribution system. Given the amount of generation and

⁶ This requirement will not prevent the project from being interconnected to the distribution system if adequate arrangements are made in the interconnection agreement to fund this scope of work.

the strength of the distribution system, SCE will not require a harmonic study but strongly encourages that the applicant completes a harmonic study during the Facility Study Phase. During the commissioning test of the generation system, SCE will be part of the commissioning test, install power quality equipment to verify that the total harmonic contribution from the generation system to the SCE meets the required standards. If during the commissioning test, it is found that the projects do not meet the harmonic standards, the project will not be allowed to interconnect to the SCE system until the harmonic deviations are rectified. Therefore, it is encouraged that the applicant completes a harmonic study during the Facility Study to insure that the harmonic requirements are met. If the applicant chooses to complete a harmonic study, SCE will then provide the required SCE distribution system data that are to be used as part of the harmonic study.

IV. PART A: GENERAL DESCRIPTION OF IDENTIFIED UPGRADES

Distribution Upgrades

Distribution Upgrades will include the installation of a 4-way Automated Pad Mounted Gas Switch and [REDACTED] Bi-directional transducer. The total cost estimate for the distribution upgrades is \$111.0 K.

Interconnection Facilities

Interconnection Facilities will be required to interconnect this generation project. These facilities include approximately 300 feet of underground primary 1000 JCN cable, a RCS controller, 12 kV metering CTs and VTs, metering, and associated wiring. The total cost estimate for the distribution interconnection facilities is \$124.0K.

Customer Equipment

The interface protection will be provided by the applicant and will include a 12 kV circuit breaker which was installed at the applicant-owned 12 kV switchgear. The applicant's protection has been coordinated with SCE's Estero Substation circuit breaker controls to provide adequate protection for the distribution system. The relay settings have been reviewed and approved by SCE and a certified timed trip testing report was provided to SCE prior to energizing the switchgear.

The switchgear must meet SCE's published Electrical Service Requirements (ESR). Drawings required by the ESR where submitted, shall be reviewed, modified, and approved by SCE prior to release for fabrication/purchase of the equipment.

Applicant generation interconnection equipment must comply with SCE's Interconnection Handbook in regards to generation protection and lockable-visible disconnecting means at the point of interconnection.

Interconnection Facilities Study

An Independent Facilities Study will be required to determine cost and time to complete the required interconnection facilities for the [REDACTED]

V. NON-BINDING ORDER OF MAGNITUDE COST ESTIMATE

- Non-binding order of magnitude cost estimates for the required interconnection facilities and system upgrades are as follows:

Distribution Upgrades \$ 88.0 K⁷

- 4-way Automated Pad Mounted Gas Switch

Distribution Upgrades (Substation) \$ 23.0 K⁷

- Bi-directional Transducer*

Interconnection Facilities Upgrades \$ 124.0 K⁷

- Approximately 300 feet of primary cable (1000 JCN)
- Remote Control Switch
- 12 kV Metering, CTs, PTs, and associated wiring

Telemetry Requirements⁸ \$ 5.0 K⁷

- Remote Terminal Unit
- Telecommunication System for RTU

Total non-binding order of magnitude cost estimate \$240.0 K⁹

⁷ Cost Estimate includes 35% ITCC. Cost estimate are in 2012 Dollars.

⁸ Cost and scope of telemetry may be reduced. Details will be provided once the new telemetry system methods are completed.

⁹ Cost Estimate includes 35% ITCC. Cost estimate are in 2012 Dollars.

VI. PART A: SUMMARY

The Part A Independent System Impact Study showed:

1. Distribution Upgrades will include the installation of a new 4-way Pad Mounted Gas Switch and on 3-phase Bi-directional transducer.
2. Interconnection Facilities will include the approximately 300 feet of underground primary 1000 JCN cable, a RCS controller, 12 kV metering CTs and VTs, metering, and associated wiring.
3. Real time telemetry will be required. A Remoter Terminal Unit will be used to provide the telemetry requirements.
4. Interconnection service and distribution service pursuant to the WDAT would be expected to commence within 6-8 months of executing a Generator Interconnection Agreement ("GIA") and associated Distribution Service Agreement.
5. Non-binding order of magnitude cost estimates for the required interconnection facilities and 12 kV system upgrades are as follows, these do not include any costs driven by Part B of the study.


12 kV Distribution Upgrades	\$88.0 K ¹⁰
Substation Distribution Upgrades	\$23.0 K ¹⁰
Interconnection Facilities/Automation	\$124.0 K ¹⁰
Telemetry Requirements	\$5.0 K ¹⁰
<hr/>	
Total non-binding order of magnitude cost estimate	\$240. K ¹⁰

¹⁰Cost Estimate includes 35% ITCC. Cost estimate are in 2012 Dollars.

6. This Independent System Impact Study is based on various technical data previously provided by the applicant. If any of that information changes significantly, as determined by SCE, the results of this study may no longer be appropriate and may necessitate a new study.
7. The Independent System Impact Study is based on applicant's queue position. Additional studies may be needed if any changes occur in the projects ahead in the queue.
8. Applicant is responsible for the cost of civil work which is required for the distribution and interconnection electrical facilities.
9. Current distribution standards are being updated to address generation interconnection systems. The proposed method of service in this report may change according on final design to comply with the updated distribution design standards.
10. An Independent Facilities Study detailing required scope and cost of the identified upgrades is required to proceed with the project.
11. Upgrades identified are general and preliminary descriptions only. The costs indicated are non-binding order of magnitude only. The schedule is projected and preliminary.
12. Cost does not include any associated with environmental surveys or reviews needed for the licensing or permitting of the proposed generation project.

ATTACHMENT #1
System Without Proposed Project

ATTACHMENT #2
System With Proposed Method of Service.



ATTACHMENT B – [REDACTED] IMPACT STUDY REPORT

CAISO Controlled Bulk System

Short Circuit Duty:

Since the project is connecting to low voltage level of SCE distribution system and consists inverter facilities which have limited short-circuit duty contribution, the SCD analysis determined no impact on SCE's high-voltage bulk power system after interconnecting the project.

Power Flow Study:

Power flow analyses were also performed using the Peak and Off-Peak full loop base cases to evaluate system performance due to the interconnection of WDAT462-ISP generation project.

The Off-Peak load was modeled at about 60% of the Peak load. Per the directions from the CAISO, overloads identified if applicable from the Off-Peak cases were assumed to be mitigated by Congestion Management. However, upgrades are required to mitigate overloads identified in the Peak cases.

Since, WDAT462-ISP is a post Queue Cluster 4 Phase I (QC4PI) application, power flow studies were performed with all the upgrades identified in QC4PI. If any QC4PI project withdrew, upgrades related to this particular project would be removed from the base cases. In such scenario, power flow re-study would be performed. The conclusion of this ISP study would be revised.

Based on all study assumptions described above, , the power flow study results identified that the project in connection with SCE's Valley 500 kV system didn't provide system impact to SCE's bulk power system.